



## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 174

Dated: 20/06/2024

It is certified that an inspection team headed by Dr. Jayshri Bhusare (DHO Jalna) from Health Dept DHO Jalna inspected the **Infinity Podar Learn School, Gat no 196, Malkheda, Tal.-Bhokardan, Dist. Jalna, Maharashtra** on 05/06/2024 and on the basis of Water Test Report (Attached) bearing no. 1866-68 dated 18/06/2024 of District public health lab (PHED Lab) certified that the **Infinity Podar Learn School, Gat no 196, Malkheda, Tal.-Bhokardan, Dist. Jalna, Maharashtra** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

Instructions: Regular disinfection of water is recommended.

This certificate is valid till 20/06/2025

Signature with seal

:-

Name

:-

Dr. Jayshri Bhusare  
जिल्हा आरोग्य अधिकारी

Designation

:-

DHO Jalna  
जिल्हा परिषद जालना.

Name & address of the office/Department : - Dist Health Office Jalna, Dist Jalna 431203

To,

Infinity Podar Learn School

Gat no 196, Malkheda, Tal.-Bhokardan, Dist. Jalna, Maharashtra

(Name and address of the institution)

  
Directors


  
Directors

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies

INFIDOC WELFARE FOUNDATION

  
Principal

Infinity Podar Learn School Malkheda

Tq. Bhokardan Dist. Jalna



महाराष्ट्र राज्य सार्वजनिक आरोग्य सेवा "अ"

जिल्हा सार्वजनिक आरोग्य प्रयोगशाळा, जालना.

नर्सिंग ट्रेनिंग सेंटर बिल्डींग सामान्य रुग्णालय परिसर, जालना.  
दुरध्वनी क्रमांक ०२४८२- २९७५११, ईमेल :- dphljn@gmail.com

पाणी नमुन्यांचा सुक्ष्मजीवीय अहवाल

पाठविषा-याचा नाव व पत्ता :- **श्री आर्ची. प्रा. आ. के. आन्ना**  
पाठविषा-याचे पत्र क्रमांक व दिनांक :- **14/6/24**  
प्रयोगशाळा संदर्भ क्रमांक :- **6020-6021**

नमुना घेतल्याचा दिनांक :- **14/6/24**  
नमुना पोहचल्याचा दिनांक :- **14/6/24**  
नमुना तपासणीचा दिनांक :- **14/6/24**

अ.क्र.	पाणी नमुन्याचे विवरण	प्रती १०० मि.ली. नमुन्यातील संभाव्य सुक्ष्मजंतूची संख्या		इतर अभिप्राय
		कोलीफॉर्मस	थर्मोटॉलरंट कोलीफॉर्मस	
1.	आपल्या संदर्भीय पत्रानुसार पाणी नमुना क्र 2) पोददार शाका मालखेडा - फिल्टर	0	—	पिण्यास योग्य
2.	पाणी नमुना क्र 1) पोददार शाका मालखेडा - विट्टर	716	5	पिण्यास अयोग्य

अभिप्राय: पिण्यास अयोग्य पाण्यावर योग्य प्रमाणात क्लोरीनची प्रक्रिया केल्यानंतर व सुक्ष्मजीवीय पुनर्तपासणी नंतर पिण्यास योग्य असल्याची खात्री झाल्यावर ते पाणी पिण्यासाठी वापरता येईल.

अहवाल क्रमांक:- **1866-68**

दिनांक:- **18 JUN 2024**

प्रत: १. जिल्हा आरोग्य अधिकारी जि.प. जालना.  
२. जिल्हा शल्यचिकित्सक सामान्य रुग्णालय .....  
३. गट विकास अधिकारी प.स. **भोकरदन**

**M. J.**  
Principal

**Ayale**  
कनिष्ठ वैज्ञानिक अधिकारी  
सार्वजनिक आरोग्य प्रयोगशाळा जालना

Trinity Podar Learn School Malkhed  
Tq. Bhokardan Dist. Jalna





महाराष्ट्र MAHARASHTRA

2023

स्टॅम्प घेणाऱ्याचे नांव

कोणास

94AA 020849



अ.क्र.

3585

दिनांक

26/5/2024

किंमत

१००/-

विलेय विद्वान् शिरसा  
- य. वि. वि.



क.अ.पठाण  
मुद्रांक/स्टॅम्प पेपर विक्रेता, सिल्लोड  
परवाना क्र. ABD-040  
परवाना कोड क्र. 3105020

Revised Letter

**Maharashtra State Public Health Service "A"**

**District Public Health Laboratory, Jalna**

Nurses Training Center Building in General Hospital Area, Jalna

Phone No. 02482-297511 Email:- dphljl@n@gmail.com

Microbiological reports of water samples

Sender's Name and Address : Bring Medical Officer Primary Health Center

Sender's letter number and date : 14/06/2024

Laboratory reference number : 6020 - 6021

Date of sampling : 14/06/2024

Directors

Directors

Principal

INFIDOC WELFARE FOUNDATION

Unity Podar Learn School Malkhe  
Tq. Bhokardan Dist. Jalna





Date of Sample Arrival : 14/06/2024

Date of Sample Inspection : 14/06/2024


Sr No	Description of water sample	Number of potential microbes per 100 ml of sample		Other feedback
		Coliforms	Thermotolerate coliforms	
1	As per reference letter no.2 Infinity Podar Learn School-Filter	0	0	Safe for Drinking
2	As per reference letter no.1 Infinity Podar Learn School-Filter	>16	5	Unsafe for drinking

Report No. 1866-68

Copy: 1 District Health Officer Dist. P Jalna

2 District Surgeon General Hospital

3. Group Development Officer Panchayat Samiti Bhokardan



**NOTARY**  
**GOVT. OF INDIA**  
Sillod, Dist. Aurangabad M.S.  
*S.G. Dundare*  
27/06/2024  
**Adv. S. G. DUNDARE (Kewat)**  
Advocate & Notary Govt. of India  
Jai Bhavani Nagar, DHH Road, Sillod  
Tq. Sillod Dist. Aurangabad (M.S.)  
Mob 9923542407

*Madh*

*[Signature]*  
Directors  
*[Signature]*  
Directors

INFIDOC WELFARE FOUNDATION

Principal  
Infinity Podar Learn School  
Bhokardan Dist. Jalna  
Signature of Deponent  
after the attestation  
Principal  
Infinity Podar Learn School  
Bhokardan Dist. Jalna